

ADDENDUM

Project: Hagerstown Addition / Martinsburg WV Stake

Project No.: 514755713020101

Addendum No.: 2

Project Address: 1253 Mount Aetna Road, Hagerstown, MD 21740

Date: 08/17/2015

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ
of Latter-day Saints, a Utah corporation sole

From (Architect): L2M Architects

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 2 page(s).

1. Changes to prior Addenda:

a. N/A

2. Changes to Bidding Requirements:

a. Invitation to Bid

3. Changes to Conditions of the Contract:

a. N/A

4. General Clarifications:

a. Should Room 104 ceiling be noted as C4 on the finish schedule? Is there specifications for the 12" x 12" ceiling tile?

Response: Room 104 shall have a ceiling type "C1". See attached specs for 12"x12" ceiling tile – Section 13.162 09 5116 Acoustical Ceiling Tiles.

b. Should Room 104 Are draperies owner-provided and installed? A Drapery Schedule is listed on A-701, but not in the specifications. Please advise

Response: see attached spec section 13. 162 12 2200 Curtains and Drapes Addendum #2

c. Please verify which hardware is to be used for the aluminum doors; the hardware is in specification 084113 and 080601. There are quite a few differences with regard to the types of hardware and the finish between the two specification sections?

Response: spec section 08 0601 Door Hardware shall govern over spec section 08 4113 Aluminum-Framed Entrances and Storefronts with respect to door hardware. Finishes for both spec sections shall match existing conditions – Field Verify.

d. Sheet 5 of 10 of the site drawings, plan view shows "S.W.M Structure Pool Area". Is this a concrete structure with walls and floor or curb or earthen banks? The way it is drawn looks like a curb.

Response: Earthen banks.

e. Details: F1& K1 on sheet A-101 differ from structural sheet D/S-303 on cmu type.

Response: Updated sheet A-101 Delta 3 dated 8-17-15 shall govern and structural sheet S-303 shall be updated on addendum #3 to reflect design intent shown in A-101.

4. Changes to Specifications:

- a. Add attached Spec Section: 13.162 05 5214 Galvanized Steel Pipe and Tube Railing – Addendum #2
- b. Replace attached Spec Section: 13.162 -09 9113 Exterior Painted Galvanized Metal - Addendum #2 in place of 13.162 -09 9113 Exterior Painted Galvanized Metal – dated 6-24-15

5. Changes to Drawings:

- a. Sheet G-002 on A1 – Egress Plan: change note clouded as Delta 1 to read as follows: ***“Delta 2 dated 8-17-15 existing 4-hour wall fire rated wall unless note otherwise: see sheet A-101 more detail”***.
- b. Sheet AS-101 – change notes to the following:
 - a. “Stainless Sleeve – Typ.” to read as follows: ***“Delta 3 dated 8-17-15 hot-dipped galvanized sleeve Typ.”*** in the entire sheet.
 - b. Delete note “As a skateboard deterrent” from the entire sheet.
- c. Sheet A-101 – replace sheet in its entirety with attached A-101 Delta #3 8-17-15
- d. Sheet A-102 – replace sheet in its entirety with attached A-101 Delta #3 8-17-15
- e. Sheet A-201 – replace sheet in its entirety with attached A201 Delta #3 8-17-15.
- f. Sheet A-202 – replace sheet in its entirety with attached A-202 Delta #3 8-17-15.
- g. Sheet A-401 – replace sheet in its entirety with attached A-401 Delta #3 8-17-15.
- h. Sheet A-501 – replace sheet in its entirety with attached A-501 Delta #3 8-17-15.
- i. Sheet A-701 – replace sheet in its entirety with attached A-701 Delta #3 8-17-15.

End of Addendum